BV LCIE CHINA Number

 $N^\circ 1866 AB 12 AB PS 30285$



ATTESTATION

of conformity with European Directives

| Product | Console Type Air conditioner | | |
|--------------------------------|--|--|--|
| Reference | : AC140S2SK1FA (Indoor unit)+1U140S2SP1FA (Outdoor unit) | | |
| Trade mark | Haier | | |
| Issued to | Qingdao Haier Air Conditioner Electric Co., Ltd. | | |
| Address | : Haier industrial Park, No.236, Qianwangang Road, Qingdao Eco-tech Development Zone, Qingdao 266555, China | | |
| Manufacturer | Qingdao Haier Air Conditioner Electric Co., Ltd. | | |
| Technical characteristics | AC 220-240V, 50/60Hz; 7200W, 32A | | |
| The submitted sample of the ab | equipment has been tested for \mathbf{CE} marking according to following European | | |

The submitted sample of the above equipment has been tested for **S** marking according to following European Directive and following standards:

Electromagnetic Compatibility Directive 2014/30/EU

| Standards | Report number | Report date |
|------------------------------------|---------------------|-------------|
| EN 55014-1:2017 EN 55014-2:2015 | ABPS-18NO1651DTQDPB | 14/12/2018 |
| EN 61000-3-12:2011 | | |
| EN 61000-3-11:2000 | | |

The referred test report(s) show that the product complies with standard(s) recognized as giving presumption of compliance with the essential requirements in the specified European Directive

This verification does not imply assessment of the production of the product The $C \in$ marking may be affixed if all relevant and effective European Directives with $C \in$ are applicable

Shanghai (P.R. China), Dec. 14, 2018.



Yi XU Expert

This document shall not be reproduced, except in full, without the written approval of BV LCIE China. Information given in this document, are related to the tested specimen of the described electrical sample.

LCIE China Company Limited 必维欧亚电气技术咨询服务(上海)有

限公司 Version 8/2018.1.20 Building 4, No. 518, Xin Zhuan Road, CaoHejing Songjiang High-Tech Park, Shanghai, CHINA