



LCIE

BV LCIE 1866AS12ABPS30186  
CHINA  
Number 1866AF12ABPS30186

# ATTESTATION of conformity with European Directives

*Product:* Indoor unit of Air conditioner  
*Reference* AF42S2SD1FA, AF35S2SD1FA, AF25S2SD1FA  
*Issued to* Qingdao Haier Air Conditioner Electric Co., Ltd.  
*Address* Haier industrial Park, No.236, Qianwangang Road, Qingdao Eco-tech Development Zone, Qingdao 266555, China.  
*Manufacturer* Qingdao Haier Air Conditioner Electric Co., Ltd.  
*Technical characteristics* 220-240V~, 50/60Hz, 40W, Refrigerant: R32, Max. work pressure: 4,3MPa, Class I,

The submitted sample of the above equipment has been tested for **CE** marking according to following European Directive and following standards:

Low Voltage Directive 2014/35/EU

Standards	Report number	Report date
EN 60335-1:2012 +A11:2014 +A13:2017 EN 60335-2-40:2003 +A11:2004 +A12: 2005 +A1:2006 +A2:2009 +A13:2012 EN 62233:2008	ABPS-18NO1657DTQDP	21/12/2018

The referred test report(s) show that the product complies with standard(s) recognized as giving presumption of compliance with the essential requirements in the specified European Directive

This verification does not imply assessment of the production of the product  
The **CE** marking may be affixed if all relevant and effective European Directives with **CE** are applicable

Shanghai (P.R. China), Dec 21<sup>th</sup>, 2018

Yi ZONG  
Product Line Manager



This document shall not be reproduced, except in full, without the written approval of BV LCIE China.  
Information given in this document, are related to the tested specimen of the described electrical sample.

LCIE CHINA  
必维欧亚电气技术咨询服务(上海)有限公司

Building 4, No. 518, Xin Zhuan Road,  
CaoHejing Songjiang High-Tech Park,  
Shanghai P.R.C (201612)

Tel: +86 21 6195 7000  
Fax: +86 21 6195 7001  
Email: [contact@cn.bureauveritas.com](mailto:contact@cn.bureauveritas.com)

Version 3/2016.02.19